

# MAHARASHTRA INDUSTRIAL DEVELOPMENT CORPORATION

(A Government of Maharashtra Undertaking)



No. MIDC/Fire/ 1332  
Date: 03/06/2013

M/s. Bhausahab Mulik Charitable Trust.  
Plot No. P-73, MIDC, Indl. Area,  
Butibori, Nagpur.

**Sub.:- Grant of "Conditional Final No Objection Certificate" for your Educational building Plot No. P-73, MIDC, Indl. Area, Butibori, Nagpur.**

- Ref.:-** 1. This office Prov. NOC No. MIDC/Fire/888, dated 18/04/2013.  
2. Application submitted by company on single window vide No. SWC/199/1/20130522/207722, dated. 22/05/2013.  
3. Undertaking given by you on dated. 03/06/2013.

Dear Sir,

With reference to the above, a representative of this office visited your **Educational building** on 24/05/2013 on the above-mentioned address for inspection of fire fighting arrangements provided by you. Since the fire fighting arrangements provided by you were found in satisfactory working conditions but extra staircase for building till date is pending which may take some time. Considering the difficulty express by you for obtaining BCC and as per the undertaking given by you, that you will complete the extra staircase for all buildings which are ground plus one within four months time. This office is issuing a "**Conditional Final No-Objection Certificate**" for your **Educational building** having built up area admeasuring **11573.55 Sq. Mtrs.**

This certificate shall be treated valid for a period of **Four Months** from the date of issue i.e. **up to 02/10/2013**. It is your responsibility to obtain "Final NOC" on or before **02/10/2013** & renewed it every year after inspection of fire fighting installation and arrangements provided for fire safety, failing which **MIDC has all rights to initiate action against you under the provisions of Maharashtra Regional town Planning Act, 1966 for cancellation of your occupancy certificate & you shall be liable for action deemed fit under the provisions of Maharashtra Fire Prevention & Life Safety Measure Act, 2006 & MIDC shall initiate such action at your risk & cost (The cost of legal suits & administrative expense whatsoever).**

**Following Statutory Provisions under Maharashtra Fire Prevention and Life Safety Measures Act, 2006:**

- Under Section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" (hereinafter referred to as "said Act"). The applicant (developer, owner, occupier by whatever name called) shall comply with all the Fire and Life Safety measures adhering to National Building Code of India, 2005 and as amended from time to time failing which it shall be treated as a violation of the said Act.
- It is presumed that you have completed the work adhering to the provisions under **Section-3** of the said Act.
- Under sub-section (3) of Section 3**, it is responsibility of the owner or the Occupier as the case maybe, shall furnish to the Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of Jan & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in **sub-section (1)**.
- Under **sub section (4) of Section 3**, no person shall tamper with, alter, remove or cause any injury or damage to any fire prevention and life safety equipment installed in any such building or part thereof or instigate any other person to do so.





It is your responsibility to complete the construction of second staircase to maintain travel distance of 30 Mtr. within four months of time and obtained a Final Fire Approval from this office; till the Final Fire Approval is obtained from this office you will not occupy the building which may please be noted.


**The Fire Extinguishers and other fire protection systems installed by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the said system is not maintained, retrenched, this N.O.C. will stand cancelled without any notice & you will be fully responsible to loss of life or property, if any, which may please be noted.**

M/s. Bhausaheb Mulik Charitable Trust. have deposited an amount of Rs. 37542.00 vide receipt No. 004371GL14 dated 18/04/2013 towards the "Fire Protection Fund Fees".

The conditions mentioned in the "Provisional No-Objection Certificate" will remain unchanged. The undersigned reserves right to amend/suggest any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the building. **If any change of the activity or transfer or Subletting of plot or future expansion No- Objection Certificate from this office is essential.**

Thanking you.



Yours faithfully,  


(M.V. Deshmukh)  
Chief Fire Officer & Fire Advisor  
MIDC, Mumbai.

Copy to Submitted to The Executive Engineer, MIDC, Hingna, Division-I, for information.



|| Shree ||

Add. : 73, Pannase lay out, Near N.I.T. Play Ground Behind Bhende Lay out,  
NAGPUR - 22 ☎ : 0712-6450497 Fax : 0712-2244192, 2224338  
Cell. : 9371144970  
E-mail : gajananenterprises1@hotmail.com / rajendrakharahe@rediffmail.com

**Gajanan**  
ENTERPRISES

Ref. No.

Date :

## CERTIFICATE

This is to Certify that **The Principal, Bhausaheb Mulak Ayurved College & Research Hospital, Plot No. P-73, MIDC, Butibori, Nagpur** has fully equipped With Fire Extinguishers & Fire Fighting System. If any case of Fire emergency that equipment would be Sufficient. We are regularly check and filling these Fire Extinguishers & Fire Fighting System properly .

Date : 25/11/2019

Place : Nagpur



**For Gajanan Enterprises**

For GAJANAN ENTERPRISES

*A. S. Kharahe*  
Proprietor

PROPRIETOR



# Gajanan ENTERPRISES

II Shree II  
Subject to Nagpur Jurisdiction

Add. : 73, Pannase lay out, Near N.I.T. Play Ground  
Behind Bhende Lay out, NAGPUR - 22  
☎ : 0712-6450497  
Cell. : 09371144970, 09270667161  
E-mail : gajananenterprises1@hotmail.com  
rajendrakharahe@rediffmail.com

## TAX INVOICE

<b>Details of Receiver/Billed to :</b>		Original for Recipient	Duplicate for Supplier/Transporter	Triplicate for Supplier
<b>M/s.</b> <u>The principal Bhausaheb Mulak Ayurved college &amp; Research Centre Hospital</u> <b>Address</b> <u>Plot No - P 73, MIDC Butibon, Nagpur.</u> <b>GSTIN</b> _____ <b>State</b> <u>Maharashtra</u> <b>State Code</b> <u>27</u>		<b>Invoice No. :</b> <u>1421</u> <b>Date :</b> <u>20/11/2019</u> <b>Your Order No.</b> <u>Telephonic</u> <b>Date :</b> <u>19/11/19</u> <b>Delivery Memo No.</b> <u>4973</u> <b>Date :</b> <u>20/11/19</u> <b>State</b> <u>Maharashtra</u> <b>State Code</b> <u>27</u> <b>Date of Supply :</b> _____ <b>Place of Supply :</b> <u>Nagpur</u> <b>Transportation Mode :-</b> _____ <b>Vehicle No.</b> _____		

SR NO.	Name of Product/Service	Qty	Rate	Amount	Less Disc out	Taxable Value	CGST Rate	CGST Amount	SGST Rate	SGST Amount	Total
1	Rebiling of ABC Dry powder spray nos pressure type Fire Extinguisher capacity 3.6 kg	12	533/-	6396/-		6396/-	9%	576/-	9%	576/-	7548/-
2	Rebiling of Gas type Fire Extinguisher cap - 4.5 kg	05	445/-	2225/-		2225/-	9%	200/-	9%	200/-	2625/-
3	Testing of above Fire Extinguisher nos	17	70/-	1190/-		1190/-	9%	107/-	9%	107/-	1404/-
	<b>Total</b>			<b>9811/-</b>		<b>9811/-</b>		<b>883/-</b>		<b>883/-</b>	<b>11577/-</b>

**TOTAL INVOICE AMOUNT IN WORDS :** Eleven thousand Five Hundred Seventy Seven Rupees only

**Total Amount Before Tax** 9811/-

**Add : CGST** 883/-

**Add : SGST** 883/-

**Tax Amount : GST** 1766/-

**Total Amount After Tax** 11577/-

**Terms and conditions**  
No responsibility is taken for loss in transit.  
Interest @20% per annum will be charged from the date of invoice, if the payment is not received on due date.

I/We hereby certify that my/our registration certificate under the State GST Act, 2017 is in force on the date on which the sales of the goods specified in this Tax invoice is made by me/us and the transaction of sale covered by this Tax invoice has been effected by me/us and it shall be accounted for in the turnover of sales while filing of return and the due tax. If any, payable on this sale has been paid or shall be paid.  
E. & O.E.

### Bank Details

Bank Name : Vijaya Bank  
Bank Branch : 219, Bajaj Nagar Nagpur  
Bank A/C No. 506700301000173  
Bank IFSC Code : VIJB0005067

**GSTIN : 27AIXPK4179P1Z**  
**PAN : AIXPK4A79P**

**GSTIN : 27CUPPK4482D1ZB**  
**PAN : CUPPK4482D**

**Receiver's Seal and Signature**

**GST Payable on reverse Charge**

Certified that the particulars given above are true and correct

**For Gajanan Enterprises**

**Authorised Signatory**

Pande Sir 9923106382

॥ Shree ॥

**Gajanan**  
ENTERPRISES

# DELIVERY MEMO

Add. : 73, Pannase lay out, Near N.I.T. Play Ground, Behind Bhende Lay out, NAGPUR - 22  
☎ : 0712-6450497 Fax : 0712-2244192 Cell. : 09371144970

D.M. No. : 4973

Date 20/11/2019

To,

The Principal, Bhakusabheb Prulak, Ayurved college  
& Research Hospital, Plot No. P-73, MIDC

Your Order No.

Batibori, Nagpur.

Date

Sr. No.	PARTICULARS	Qty.	Rate	
			Rs.	Ps.
1)	Rebilled & Tested of ABC Dry powder stored pressure type Fire Extinguisher capacity: 6kg	12 nos.		
2)	Rebilled & Tested of CO2 Gas type Fire Extinguisher capacity: 5.5kg	05 nos.		

GSTIN : 27CUPPK4482D1ZB

Received in good condition & as per order  
Please Sign and return

Receiver's Signature

For Gajanan Enterprises

Proprietor



Date : 20/11/2019

### REFILLING CERTIFICATE OF FIRE EXTINGUISHERS

To,

The Principal  
Bhawsabeb Mulark Ayurved College  
& Research Hospital  
Plot No. P-73, MIDC, Bedion,  
Nagpur.

Sr. No	Type of Extinguisher	Size	Qty.	Testing Dt.	Refilling Dt.	Due Dt.
1	ABC Dry powder	6kg	12nos.	20/11/2019	20/11/2019	19/11/2020
2	Car Gas type	2.5kg	05nos.	—	—	—
3						
4						
5						
6						
7						
8						
9						
10						


Certified that the above Fire extinguisher/ Fire equipment material have been perfectly checked tested and assured that the above fire extinguisher's /fire equipments material can be controlled in emergency time of fire

For Gajanan Enterprises

  
Proprietor



LIST OF EQUIPEMENTS FOR FIRE SAFTY		
SR.NO	PARTICULARS OF ITEMS	QTY
1	ABC FIRE EXTINGUISHERS	55 NO
2	CO2 FIRE EXTINGUISHERS	10 NOS
3	HOSE REEL	6 NOS
4	DOWN COMER	3 NOS
5	TERRACE LEVEL TANK	30000 LIT
6	BOOSTER PUMP	3NOS 900LPM ELECTRIC DRIVEN PUMP

  
 28/11/19  
 Principal  
 Bhausaheb Mulak Ayurved College  
 & Research Hospital, Butibori, Nagpur







सदर लायसन्स महाराष्ट्र आग प्रतिबंधक व जीवसंरक्षक उपाययोजना अधिनियम, २००६ च्या कलम ९ (५) व १८ (२) नुसार देण्यात आले असून या अधिनियमाच्या कलम २ (७) मधील व्याख्येनुसार राज्यातील सर्व संपादक प्राधिकरणात तसेच कलम २ (१२) मधील व्याख्येनुसार सर्व नियोजन प्राधिकरणात वैध राहिल.

१) लायसन्स, -

- क) अहस्तांतरणीय असेल,
- ख) जर लायसन्स निर्लंबित किंवा राह करण्यत आले नसेल तर लायसन्स देण्यात आल्यापासून एक वर्षापर्यंत वैध असेल,
- ग) लायसन्स समाप्त होण्यापूर्वी, तशी इच्छा असल्यास, नूतनीकरण योग्य असेल.
- २) क) भागीदार, संचालक किंवा सदस्य,
- ख) लायसन्सप्राप्त अधिकरणाच्या कार्यालयाचा घत्ता, बाबाबतीत कोणतेही बदल करायचे असल्यास, महाराष्ट्र अग्निशमन सेवा संचालनालय तात्काळ कळविण्यात यावे.
- ३) लायसन्स प्राप्त अधिकरण नेहमी ते करीत असलेले किंवा त्याने केलेले काम, संचालक, किंवा संचालक यांनी प्राधिकृत केलेला कोणताही अग्निशमन अधिकारी यांना तपासणीसाठी खुले ठेविले.
- ४) लायसन्स प्राप्त अधिकरण हे आग प्रतिबंधक व उपाययोजना करण्या संबंधात व अन्य त्वांनुबंधिक पार पाडलेल्या प्रत्येक इमारतीसाठी तपासना-अ" मध्ये प्रमाणपत्र देतील आणि अशा इमारतीची तपासणी करून या इमारतीमध्ये त्वांनुबंधाकडून बनविण्यात आलेली साधने सुरक्षित व कार्यक्षम स्थितीत ठेवण्यात आल्या नंतर प्रत्येक जागेबारी व जुलै महिन्या मध्ये तपासना-ब" मध्ये सहामास प्रमाणपत्र देतील.

This Licence has been issued under the provisions in Section 9(5) and Section 18(2) and is valid in all Local Authorities as defined in Section 2(7) & Local Planning Authorities as defined in section 2(12) of The Maharashtra Fire Prevention and Life Safety Measures Act, 2006.

1. The licence shall be -
  - a) non-transferable.
  - b) valid for one year from the date of issue, unless suspended or cancelled earlier.
  - c) renewable, if so desired, before expiry of the licence.
2. Changes, if any, in respect of the -
  - a) Partners, Directors or Members,
  - b) Address of the office of the Licensed Agency.
 shall be forthwith reported to the Directorate of Maharashtra Fire Services.
3. The Licensed Agency shall always keep the work, executed, or being executed by it, open for inspection by the Director, or any Fire Officer authorized by the Director.
4. The Licensed Agency shall issue a certificate in Form "A" to the client in respect of the works executed by them and also issue a six monthly certificate in Form "B", in every January and July after carrying out inspection of the Fire Prevention and Life Safety Measures work executed, being executed by them is in good repair and efficient condition at all times.



Govt. of Maharashtra  
**Directorate of Maharashtra F**  
 Vidyavanagar, Hans Bhugra A  
 Santacruz (East), Mumbai - 40  
 \*Tel No. 2667 7555 \*Fax No. 21  
 \*www.mahafireservice.go



This Licence has been issued under the provisions in Section 9(5) and Section 18(2) and is valid in all Local Authorities as defined in Section 2(7) & Local Planning Authorities as defined in section 2(12) of The Maharashtra Fire Prevention and Life Safety Measures Act, 2006.

1. The licence shall be -

- non-transferable,
- valid for one year from the date of issue, unless suspended or cancelled earlier,
- renewable, if so desired, before expiry of the licence

2. Changes, if any, in respect of the -

- Partners, Directors or Members,
  - Address of the office of the Licensed Agency.
- shall be forthwith reported to the Directorate of Maharashtra Fire Services.

3. The Licensed Agency shall always keep the work, executed, or being executed by it, open for inspection by the Director, or any Fire Officer authorized by the Director.

4. The Licensed Agency shall issue a certificate in Form "A" to the client in respect of the works executed by them and also issue a six monthly certificate in Form "B", in every January and July after carrying out inspection of the Fire Prevention and Life Safety Measures work executed, being executed by them is in good repair and efficient condition at all times.



Govt. of Maharashtra  
**Directorate of Maharashtra Fire Ser**  
 Vidyanagari, Hans Bhugra Marg,  
 Santacruz (East), Mumbai - 400 098.  
 \*Tel No. 2667 7555 \*Fax No. 2666 0287  
 \*www.mahafireservice.gov.in

हात लायसन्स मर्याद आत प्रतिबंधक व अधिकारिता  
 लायसन्स अक्टिवाट, २००६ च्या कलम ९ (५) व १८ (२) प्रसार  
 प्राधिकारिता अंतर्गत, २००६ च्या कलम २ (७) मधील स्थानीयगुस्त  
 इमारत आले अशा व/अथवा अग्निप्रसाराच्या कलम २ (१२) मधील  
 लायसन्स हॉल इमारत प्राधिकारिता अंतर्गत कलम २ (१२) मधील  
 लायसन्स हॉल इमारत प्राधिकारिता अंतर्गत कलम २ (१२) मधील

१) लायसन्स -

क) अडस्तारतीय असेल,

ख) जर लायसन्स मितलित किंवा वद भरण्यात आले नसेल  
 तर लायसन्स देण्यात आल्यापासून एक वर्षांपर्यंत वैध  
 असेल,

ग) लायसन्स संपादन होण्यापूर्वी, तरी इच्छा असल्यास,  
 नूतनीकरण होऊन असेल.

घ) क) भागीदार, संचालक किंवा सदस्य,

ख) लायसन्समार्फत अधिकारिताच्या कार्यालयाच्या घला,  
 वाचकरीत कोतेही बदल करायवाचे असल्यास,  
 महापुत्र अग्निसमन सेवा संचालनालय तात्काळ कळविण्यात  
 यावे.

३) लायसन्स प्राप्त अधिकृत नेटवर्क ते करीत असलेले किंवा त्याने  
 केलेले काम, संचालक, किंवा संचालक यांनी प्राधिकृत केलेला  
 नॅप्सादी अग्निसमन अधिकारी यांना लायसन्सीसाठी खुले ठेविले.

४) लायसन्स प्राप्त अधिकृत हे आत प्रतिबंधक व उपाययोजना  
 कल्या संचालक व अन्य सदानुबोधिक पार पडलेल्या प्रत्येक इमारतीसाठी  
 मनुष्य-अ" मध्ये प्रमाणपत्र देतील आणि अश्या इमारतीची लायसन्सी  
 करून वा इमारतीमध्ये त्यांच्याकडून बसविण्यात आलेली लायसन्सी  
 पुर्वित व कार्यरत स्थितीत ठेवण्यात आल्या बद्दल प्रत्येक जानेवारी व  
 जुलै महिन्या मध्येमनुष्य-ब" मध्ये सहामासी प्रमाणपत्र देतील.



License to act as Licensed Agency for the purpose of Fire Prevention And Life Safety Measures

Licence M  
Measures

Date: 12/12/2012

Licence is hereby granted / renewed under the provisions of sub-section (3) of section 9 of the Maharashtra Fire Prevention and Life Safety Measures Act, 2006 (Mah III of 2007) to M/s. Gajanan Enterprises

having their registered office at Plot No. 90, Adinivas,

LORENZ, Opp. Mad. Nda. No. 10.

Amravati Road, Nagpur 440023 to act as a

Act for execution of the Fire Prevention and Life Safety

### Measures in relation to:

- 1) Fire Fighting System installation such as hydrants, sprinklers, pumping, etc
- 2) Detection and Fire suppression system
- 3) Passive protection such as cable protection, fire doors, etc

doors, etc

Subject to the provisions of sub-section (4) of section 9 of the Maharashtra Fire Prevention and Life Safety Measures Rule, 2009, the licence to

12.12.2018

11.12.2019

... be valid for a period from

महाराष्ट्र शासन  
महाराष्ट्र अग्निशमन सेवा संचालनालय

चिष्टानगरी, हंस भुद्धा मार्ग,

सांताक्रुझ (पूर्व), मुंबई - ४०० ०६८.

टेलि.नं. २६६७०४२८, फॅक्समनं. २६६६०२८७.

[www.mahafireservice.gov.in](http://www.mahafireservice.gov.in)

(प्र.सू.रागादळ)

संस्कृतशाला,

महाराष्ट्र अग्निशमन सेवा

U.S. DEPT. OF AGRICULTURE

7600-2626-10000

[illegible][illegible][illegible]

(c) are there any other methods?

(Deborah and I have argued)

2. Intermittent (unreliable) source of energy

इ.स. १९०७ ई. अक्टोबर १० तारीख को कलकत्ता १९०७ ई. संख्या १३३

一、  
 二、  
 三、  
 四、  
 五、  
 六、  
 七、  
 八、  
 九、  
 十、

... ..

1890

[illegible]

*[Faint handwritten notes, possibly "The little party..."]*

המחלקה הכלכלית והמסחרית

...and ...

*[Faint handwritten notes at the bottom of the page]*

10. The following information is taken from the financial statements of the company for the year ended 31st March 2018:



# BHAUSAHEB MULIK CHARITABLE TRUST

140, Rajvilla, Khamla, Nagpur (M.S.)-440025

Ph. No. 0712-2283543, 2283220

Regd. No. E-1740(N)

President

**Smt. Sumanmala B. Mulak**

Secretary

**Shri Rajendra B. Mulak**

Minister of State,  
Govt. of Maharashtra

Ref. No. BMCE/2012-13/BMCE-Corres/410/772

Dt. : 27-04-2013

To,

M/S Gajanan Enterprises,  
90, Adiwasi Layout, opp. Wadi Naka,  
Amravati Road, NAGPUR-23.

Ref.: Your quotation no. GE/HQT/BMCT/2013, Date: 25/04/2013 regarding fire fighting system installation.

Subject:- Placement of order.

Dear Sir,

With reference to above and our personal discussion we are pleased to place the order as follows.

- 1) Complete installation of fire fighting system ( Sr. No. 1 to 13 as per your quotation ) valued at Rs. 4,43,112/-
- 2) VAT 12.5% Extra for Sr. No. 3 to 9 and 12.  
VAT 5% Extra for Sr. No. 1, 2, 10 and 11.
- 3) Discount 5% on order value.
- 4) Payment: 50% Advance with order, 40% against deliver of material, 5% against completion and balance 5% on final testing.
- 5) Time period: Total time period for completion of work and obtaining final N.O.C from competent authority on or before date 25/05/2013.
- 6) Scope of work: Supply, fabrication, erection, testing & commissioning of a) Down corner systems b) Hose reel system, as per MIDC guidelines (letter enclosed) obtaining final N.O.C from competent authority.

Kindly acknowledge the receipt and acceptance of order.

*R.H.C.*

Principal  
Bhausaheb Mulik College of Engineering  
Butibori, Nagpur.



Enclosure: 1) Your quotation no. GE/HQT/BMCT/2013, dt. 25/4/2013.

2) MIDC letter no.: MIDC/FIRE/PROV\_NOC/888, dt: 18/04/2013.

*Received by  
original  
27/4/13*